

ENVIRONMENTAL LABWORKS, INC.

September 29, 2016

Mr. John Willabay
 Catskill Central School District
 347 West Main St.
 Catskill, NY 12414

Dear Mr. Willabay,

The following are results of the analyses performed on water samples from **Catskill Elementary School, 770 Embought Rd., Catskill, NY** received at the laboratory on 09/21/16.

Date/Time Collected: 09/20/16 5:05-7:16am First Draw
 Collected By: J. Willabay
 Sample ID: 09211614A:0-1 to 4-10
 Secondary Lab ID: CS162462-510

PARAMETER				
EPA 200.8	ID	LOCATION	RESULTS	ACTION LEVEL
Lead	0-1	136-SF-E	<0.001 mg/L	0.015 mg/L
	0-2	Kit-RRF-E	<0.001 mg/L	0.015 mg/L
	0-3	Kit-WS1-E	0.0109 mg/L	0.015 mg/L
	0-4	Kit-WS2-E	0.00156 mg/L	0.015 mg/L
	0-5	Kit-WS3-E	<0.001 mg/L	0.015 mg/L
	0-6	Kit-WS4-E	<0.001 mg/L	0.015 mg/L
	0-7	138-RRF-E	0.00146 mg/L	0.015 mg/L
	0-8	137-RRF-E	<0.001 mg/L	0.015 mg/L
	0-9	129-DF-E	<0.001 mg/L	0.015 mg/L
	0-10	129-SF-E	0.00204 mg/L	0.015 mg/L
	1-1	1RH-DF-1-E	<0.001 mg/L	0.015 mg/L
	1-2	1RH-DF-2-E	<0.001 mg/L	0.015 mg/L
	1-3	1RH-RRFG-1-E	<0.001 mg/L	0.015 mg/L
	1-4	1RH-RRFG-2-E	<0.001 mg/L	0.015 mg/L
	1-5	1RH-RRFB-1-E	<0.001 mg/L	0.015 mg/L
	1-6	1RH-RRFB-2-E	<0.001 mg/L	0.015 mg/L
	1-8	MO-RRF-E	<0.001 mg/L	0.015 mg/L
	1-9	105-DF-E	<0.001 mg/L	0.015 mg/L
	1-10	105-SF-E	<0.001 mg/L	0.015 mg/L

ENVIRONMENTAL LABWORKS, INC.

Catskill Elementary School - 09211614A

PARAMETER EPA 200.8	ID	LOCATION	RESULTS	ACTION LEVEL
Lead	2-1	105-RRF-E	0.00123 mg/L	0.015 mg/L
	2-2	106-DF-E	<0.001 mg/L	0.015 mg/L
	2-3	106-SF-E	<0.001 mg/L	0.015 mg/L
	2-4	106-RRF-E	<0.001 mg/L	0.015 mg/L
	2-5	107-DF-E	<0.001 mg/L	0.015 mg/L
	2-6	107-SF-E	<0.001 mg/L	0.015 mg/L
	2-7	107-RRF-E	<0.001 mg/L	0.015 mg/L
	2-8	108-DF-E	<0.001 mg/L	0.015 mg/L
	2-9	108-SF-E	<0.001 mg/L	0.015 mg/L
	2-10	108-RRF-E	0.00105 mg/L	0.015 mg/L
	3-1	111-DF-E	<0.001 mg/L	0.015 mg/L
	3-2	111-SF-E	<0.001 mg/L	0.015 mg/L
	3-3	111-RRF-E	0.00118 mg/L	0.015 mg/L
	3-5	112-SF-E	<0.001 mg/L	0.015 mg/L
	3-6	112-RRF-E	0.00504 mg/L	0.015 mg/L
	3-7	113-DF-E	<0.001 mg/L	0.015 mg/L
	3-8	113-SF-E	<0.001 mg/L	0.015 mg/L
	3-9	113-RRF-E	<0.001 mg/L	0.015 mg/L
	3-10	114-DF-E	<0.001 mg/L	0.015 mg/L
	4-1	114-SF-E	<0.001 mg/L	0.015 mg/L
	4-2	114-RRF-E	0.00128 mg/L	0.015 mg/L
	4-3	163-DF-E	<0.001 mg/L	0.015 mg/L
	4-4	163-SF-E	<0.001 mg/L	0.015 mg/L
	4-5	163-RRF-E	<0.001 mg/L	0.015 mg/L
	4-6	164-DF-E	<0.001 mg/L	0.015 mg/L
	4-7	164-SF-E	<0.001 mg/L	0.015 mg/L
	4-8	164-RRF-E	<0.001 mg/L	0.015 mg/L
	4-9	167-DF-E	<0.001 mg/L	0.015 mg/L
	4-10	167-SF-E	<0.001 mg/L	0.015 mg/L

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
ELAP #10824

ENVIRONMENTAL LABWORKS, INC.

Catskill Elementary School - 09211614A

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #10854. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

If you have any questions or require any additional services, please do not hesitate to contact us at 845-236-7823.

Thank you,

Trudie Lund, for
Anthony J. Falco
Laboratory Director