

ENVIRONMENTAL LABWORKS, INC.

September 29, 2016

Mr. John Willabay
Catskill Central School District
347 West Main St.
Catskill, NY 12414

Dear Mr. Willabay,

The following are results of the analyses performed on water samples from **Catskill Elementary School, 770 Embought Rd., Catskill, NY** received at the laboratory on 09/21/16.

Date/Time Collected: 09/21/16 5:15-6:59am First Draw
Collected By: J. Willabay
Sample ID: 09211614C:10-1 to 14-10
Secondary Lab ID: CS162561-79, CS162589-618

PARAMETER				
EPA 200.8	ID	LOCATION	RESULTS	ACTION LEVEL
Lead	10-1	156-BRRF-E	<0.001 mg/L	0.015 mg/L
	10-2	156-GRRF-E	<0.001 mg/L	0.015 mg/L
	10-3	156-DF-1-E	<0.001 mg/L	0.015 mg/L
	10-4	156-DF-2-E	<0.001 mg/L	0.015 mg/L
	10-5	156-DF-3-E	<0.001 mg/L	0.015 mg/L
	10-6	156-DF-4-E	<0.001 mg/L	0.015 mg/L
	10-7	2BH-WRRF-E	<0.001 mg/L	0.015 mg/L
	10-8	2BH-MRRF-E	<0.001 mg/L	0.015 mg/L
	10-9	248-DF-E	<0.001 mg/L	0.015 mg/L
	10-10	248-SF-E	<0.001 mg/L	0.015 mg/L
	11-1	249-DF-E	<0.001 mg/L	0.015 mg/L
	11-2	249-SF-E	<0.001 mg/L	0.015 mg/L
	11-3	250-DF-E	<0.001 mg/L	0.015 mg/L
	11-4	250-SF-E	<0.001 mg/L	0.015 mg/L
	11-5	250-RRF-E	<0.001 mg/L	0.015 mg/L
	11-6	253-DF-E	<0.001 mg/L	0.015 mg/L
	11-7	253-SF-E	<0.001 mg/L	0.015 mg/L
	11-9	254-DF-E	<0.001 mg/L	0.015 mg/L
	11-10	254-SF-E	<0.001 mg/L	0.015 mg/L

ENVIRONMENTAL LABWORKS, INC.

ELAP #10824

Catskill Elementary School - 09211614C

PARAMETER EPA 200.8	ID	LOCATION	RESULTS	ACTION LEVEL
Lead	12-1	255-DF-E	<0.001 mg/L	0.015 mg/L
	12-2	255-SF-E	<0.001 mg/L	0.015 mg/L
	12-3	256-DF-E	<0.001 mg/L	0.015 mg/L
	12-4	256-SF-E	<0.001 mg/L	0.015 mg/L
	12-5	257-DF-E	<0.001 mg/L	0.015 mg/L
	12-6	257-SF-E	<0.001 mg/L	0.015 mg/L
	12-7	263-SF-1-E	0.00551 mg/L	0.015 mg/L
	12-8	263-SF-2-E	<0.001 mg/L	0.015 mg/L
	12-9	263-SF-3-E	<0.001 mg/L	0.015 mg/L
	12-10	263-DF-E	<0.001 mg/L	0.015 mg/L
	13-1	266-DF-E	<0.001 mg/L	0.015 mg/L
	13-2	266-SF-E	<0.001 mg/L	0.015 mg/L
	13-3	267-DF-E	<0.001 mg/L	0.015 mg/L
	13-4	267-SF-E	<0.001 mg/L	0.015 mg/L
	13-5	268-DF-E	<0.001 mg/L	0.015 mg/L
	13-6	268-SF-E	<0.001 mg/L	0.015 mg/L
	13-7	269-DF-E	<0.001 mg/L	0.015 mg/L
	13-8	269-SF-E	<0.001 mg/L	0.015 mg/L
	13-9	272-DF-E	<0.001 mg/L	0.015 mg/L
	13-10	272-SF-E	<0.001 mg/L	0.015 mg/L
	14-1	273-DF-E	<0.001 mg/L	0.015 mg/L
	14-2	273-SF-E	<0.001 mg/L	0.015 mg/L
	14-3	274-DF-E	<0.001 mg/L	0.015 mg/L
	14-4	274-SF-E	<0.001 mg/L	0.015 mg/L
	14-5	275-DF-E	<0.001 mg/L	0.015 mg/L
	14-6	275-SF-E	<0.001 mg/L	0.015 mg/L
	14-7	228-DF-E	<0.001 mg/L	0.015 mg/L
	14-8	228-SF-E	0.00451 mg/L	0.015 mg/L
	14-9	227-DF-E	<0.001 mg/L	0.015 mg/L
	14-10	227-SF-E	0.00374 mg/L	0.015 mg/L

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
ELAP #10824

ENVIRONMENTAL LABWORKS, INC.

Catskill Elementary School - 09211614C

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #10854. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

If you have any questions or require any additional services, please do not hesitate to contact us at 845-236-7823.

Thank you,

Trudie Lund, for
Anthony J. Falco
Laboratory Director