

**ENVIRONMENTAL LABWORKS, INC.**

---

September 29, 2016

Mr. John Willabay  
Catskill Central School District  
347 West Main St.  
Catskill, NY 12414

Dear Mr. Willabay,

The following are results of the analyses performed on water samples from **Catskill Elementary School, 770 Embought Rd., Catskill, NY** received at the laboratory on 09/21/16.

Date/Time Collected: 09/20/16 7:17-8:23am; 09/21/16 4:22-5:06am First Draw  
Collected By: J. Willabay  
Sample ID: 09211614B:5-1 to 9-10  
Secondary Lab ID: CS162511-60

PARAMETER				
EPA 200.8	ID	LOCATION	RESULTS	ACTION LEVEL
Lead	5-1	167-RRF-E	<0.001 mg/L	0.015 mg/L
	5-2	168-DF-E	<0.001 mg/L	0.015 mg/L
	5-3	168-SF-E	<0.001 mg/L	0.015 mg/L
	5-4	168-RRF-E	<0.001 mg/L	0.015 mg/L
	5-5	169-DF-E	<0.001 mg/L	0.015 mg/L
	5-6	169-SF-E	<0.001 mg/L	0.015 mg/L
	5-7	169-RRF-E	<0.001 mg/L	0.015 mg/L
	5-8	170-DF-E	<0.001 mg/L	0.015 mg/L
	5-9	170-SF-E	<0.001 mg/L	0.015 mg/L
	5-10	170-RRF-E	<0.001 mg/L	0.015 mg/L
	6-1	171-DF-E	<0.001 mg/L	0.015 mg/L
	6-2	171-SF-E	<b>0.00753</b> mg/L	0.015 mg/L
	6-3	174-SF-1-E	<0.001 mg/L	0.015 mg/L
	6-4	174-SF-2-E	<0.001 mg/L	0.015 mg/L
	6-5	174-SF-3-E	<b>0.00116</b> mg/L	0.015 mg/L
	6-6	174-DF-E	<b>0.00108</b> mg/L	0.015 mg/L
	6-7	179-DF-E	<0.001 mg/L	0.015 mg/L
	6-8	179-SF-E	<0.001 mg/L	0.015 mg/L
	6-9	179-RRF-E	<0.001 mg/L	0.015 mg/L

**ENVIRONMENTAL LABWORKS, INC.**

ELAP #10824

Catskill Elementary School - 09211614B

PARAMETER EPA 200.8	ID	LOCATION	RESULTS	ACTION LEVEL
Lead	6-10	180-DF-E	<0.001 mg/L	0.015 mg/L
	7-1	180-SF-E	<0.001 mg/L	0.015 mg/L
	7-2	180-RRF-E	<b>0.00119</b> mg/L	0.015 mg/L
	7-3	181-DF-E	<0.001 mg/L	0.015 mg/L
	7-4	181-SF-E	<0.001 mg/L	0.015 mg/L
	7-5	181-RRF-E	<b>0.00893</b> mg/L	0.015 mg/L
	7-6	182-DF-E	<0.001 mg/L	0.015 mg/L
	7-7	182-SF-E	<0.001 mg/L	0.015 mg/L
	7-8	182-RRF-E	<0.001 mg/L	0.015 mg/L
	7-9	1BH-DF-1-E	<0.001 mg/L	0.015 mg/L
	7-10	1BH-DF-2-E	<0.001 mg/L	0.015 mg/L
	8-1	185-DF-E	<0.001 mg/L	0.015 mg/L
	8-2	185-SF-E	<0.001 mg/L	0.015 mg/L
	8-3	185-RRF-E	<0.001 mg/L	0.015 mg/L
	8-4	186-DF-E	<0.001 mg/L	0.015 mg/L
	8-5	186-SF-E	<0.001 mg/L	0.015 mg/L
	8-6	186-RRF-E	<0.001 mg/L	0.015 mg/L
	8-7	187-DF-E	<0.001 mg/L	0.015 mg/L
	8-8	187-SF-E	<0.001 mg/L	0.015 mg/L
	8-9	187-RRF-E	<0.001 mg/L	0.015 mg/L
	8-10	188-DF-E	<b>0.00239</b> mg/L	0.015 mg/L
	9-1	188-SF-E	<0.001 mg/L	0.015 mg/L
	9-2	188-RRF-E	<b>0.00452</b> mg/L	0.015 mg/L
	9-3	188-CB-WC-E	<0.001 mg/L	0.015 mg/L
	9-4	189-EWF-E	<0.001 mg/L	0.015 mg/L
	9-5	189-SF-E	<0.001 mg/L	0.015 mg/L
	9-6	189-RRF-E	<0.001 mg/L	0.015 mg/L
	9-7	1BH-GRR-1-E	<0.001 mg/L	0.015 mg/L
	9-8	1BH-GRR-2-E	<0.001 mg/L	0.015 mg/L
	9-9	1BH-BRR-1-E	<b>0.00110</b> mg/L	0.015 mg/L

PO Box 733  
Marlboro, NY 12542  
Phone 845-236-7823  
Fax 845-236-3911  
ELAP #10824

**ENVIRONMENTAL LABWORKS, INC.**

Catskill Elementary School - 09211614B

PARAMETER	ID	LOCATION	RESULTS	ACTION LEVEL
EPA 200.8				
Lead	9-10	1BH-BRR-2-E	0.00107 mg/L	0.015 mg/L

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #10854. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

If you have any questions or require any additional services, please do not hesitate to contact us at 845-236-7823.

Thank you,

*Trudie Lund, for*  
Anthony J. Falco  
Laboratory Director