

ENVIRONMENTAL LABWORKS, INC.

October 20, 2016

Mr. John Willabay
Catskill Central School District
347 West Main St.
Catskill, NY 12414

Dear Mr. Willabay,

The following are results of the analyses performed on water samples from **Catskill High School/Middle School, 341-345 West Main St., Catskill, NY** received at the laboratory on 09/30/16.

Date/Time Collected: 09/27/16 5:36-7:40am First Draw
09/28/16 4:31-5:32am First Draw
Collected By: J. Willabay
Sample ID: 09301606A:0-1 to 5-10
Secondary Lab ID: CS162993-3044

PARAMETER				
EPA 200.8	ID	LOCATION	RESULTS	ACTION LEVEL
Lead	0-1	HS-N-RRF-MS	<0.001 mg/L	0.015 mg/L
	0-2	HS-N-SF-MS	0.00104 mg/L	0.015 mg/L
	0-3	HS-N-WC-MS	<0.001 mg/L	0.015 mg/L
	0-5	MSC-GRR-SF1	<0.001 mg/L	0.015 mg/L
	0-7	MSC-BRR-SF1	<0.001 mg/L	0.015 mg/L
	0-8	MSC-BRR-SF2	<0.001 mg/L	0.015 mg/L
	0-9	MSC-SF1	0.00170 mg/L	0.015 mg/L
	0-10	MS-DLRR-SF	<0.001 mg/L	0.015 mg/L
	1-1	HS-LWR-SF	0.00482 mg/L	0.015 mg/L
	1-2	MS-103-SF1	<0.001 mg/L	0.015 mg/L
	1-3	MS-103-SF2	<0.001 mg/L	0.015 mg/L
	1-4	MS-103-SF3	0.00105 mg/L	0.015 mg/L
	1-5	MS-103-SF4	<0.001 mg/L	0.015 mg/L
	1-6	MS-1BRR-SF1	<0.001 mg/L	0.015 mg/L
	1-7	MS-1BRR-SF2	<0.001 mg/L	0.015 mg/L
	1-8	MS-WS-SF1	0.0282 mg/L	X 0.015 mg/L
	1-9	MS-WS-SF2	0.00164 mg/L	0.015 mg/L
	1-10	MS-WS-SF3	0.00184 mg/L	0.015 mg/L

ENVIRONMENTAL LABWORKS, INC.

ELAP #10824

Catskill High School/Middle School - 09301606A

PARAMETER EPA 200.8	ID	LOCATION	RESULTS	ACTION LEVEL
Lead	2-1	MS-BL-SF1	0.00401 mg/L	0.015 mg/L
	2-2	MS-BL-DF1	<0.001 mg/L	0.015 mg/L
	2-3	MS-Ceh-RRF	0.00880 mg/L	0.015 mg/L
	2-4	MS-1-GL-SF1	<0.001 mg/L	0.015 mg/L
	2-5	MS-1-GL-SF2	<0.001 mg/L	0.015 mg/L
	2-6	MS-1-GL-DF	<0.001 mg/L	0.015 mg/L
	2-7	MS-1-GRR-SF1	<0.001 mg/L	0.015 mg/L
	2-8	MS-1-GRR-SF2	0.00114 mg/L	0.015 mg/L
	2-9	MS-1-GRR-SF3	<0.001 mg/L	0.015 mg/L
	2-10	MS-23-SF1	0.00700 mg/L	0.015 mg/L
	3-1	MS-23-SF2	0.00162 mg/L	0.015 mg/L
	3-2	MS-23-SF3	0.00321 mg/L	0.015 mg/L
	3-3	MS-23-SF4	0.00135 mg/L	0.015 mg/L
	3-4	MS-24-DF	<0.001 mg/L	0.015 mg/L
	3-5	MSC-GRR-SF2	0.165 mg/L X	0.015 mg/L
	3-6	112-DF-E	<0.001 mg/L	0.015 mg/L
	3-7	HS-KPSF	0.00140 mg/L	0.015 mg/L
	3-8	HS-KPFF	0.00271 mg/L	0.015 mg/L
	3-9	HS-KSF1	<0.001 mg/L	0.015 mg/L
	3-10	HS-KSF2	0.00137 mg/L	0.015 mg/L
	4-1	MS-C-DF	<0.001 mg/L	0.015 mg/L
	4-2	MS-24-SCF1	<0.001 mg/L	0.015 mg/L
	4-9	MS-26-TSCF	0.00489 mg/L	0.015 mg/L
	4-10	MS-26-PR-SF	0.0401 mg/L X	0.015 mg/L
	5-1	MS-FAC-LSF1	0.00169 mg/L	0.015 mg/L
	5-2	MS-FAC-MSF1	0.00129 mg/L	0.015 mg/L
	5-3	MS-2GRR-SF1	<0.001 mg/L	0.015 mg/L
	5-4	MS-2GRR-SF2	0.00148 mg/L	0.015 mg/L
	5-5	MS-2GRR-DF	<0.001 mg/L	0.015 mg/L

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
ELAP #10824

ENVIRONMENTAL LABWORKS, INC.

Catskill High School/Middle School - 09301606A

PARAMETER				
EPA 200.8	ID	LOCATION	RESULTS	ACTION LEVEL
Lead	5-6	MS-2GRR-SF3	<0.001 mg/L	0.015 mg/L
	5-7	MS-3SF	0.0131 mg/L	0.015 mg/L
	5-8	MS-MO-RRF	0.00942 mg/L	0.015 mg/L
	5-9	MS-2BRR-SF1	<0.001 mg/L	0.015 mg/L
	5-10	MS-2BRR-SF2	<0.001 mg/L	0.015 mg/L

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #10854. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

If you have any questions or require any additional services, please do not hesitate to contact us at 845-236-7823.

Thank you,

Trudie Lund, for
Anthony J. Falco
Laboratory Director