

ENVIRONMENTAL LABWORKS, INC.

October 20, 2016

Mr. John Willabay
 Catskill Central School District
 347 West Main St.
 Catskill, NY 12414

Dear Mr. Willabay,

The following are results of the analyses performed on water samples from **Catskill High School/Middle School, 341-345 West Main St., Catskill, NY** received at the laboratory on 09/30/16.

Date/Time Collected: 09/29/16 5:12-7:03am First Draw
 09/30/16 7:09-7:14am First Draw
 Collected By: J. Willabay
 Sample ID: 09301606C:11-1 to 20-6
 Secondary Lab ID: CS163092-142

PARAMETER	ID	LOCATION	RESULTS	ACTION LEVEL
EPA 200.8				
Lead	11-1	HS-144-PRF	0.0616 mg/L X	0.015 mg/L
	11-2	HS-146-SC1	0.0346 mg/L X	0.015 mg/L
	11-3	HS-146-SC2	0.0246 mg/L X	0.015 mg/L
	11-4	HS-146-SC3	0.0247 mg/L X	0.015 mg/L
	11-5	HS-146-SC4	0.0705 mg/L X	0.015 mg/L
	11-6	HS-146-SC5	0.0384 mg/L X	0.015 mg/L
	11-7	HS-146-SC6	0.0550 mg/L X	0.015 mg/L
	11-8	HS-146-SC7	0.260 mg/L X	0.015 mg/L
	11-9	HS-146-SC8	0.228 mg/L X	0.015 mg/L
	11-10	HS-146-SC9	0.0116 mg/L	0.015 mg/L
	12-1	HS-146-SC10	0.0179 mg/L X	0.015 mg/L
	12-2	HS-146-SC11	0.0422 mg/L X	0.015 mg/L
	12-3	HS-146-SC12	0.0498 mg/L X	0.015 mg/L
	12-4	HS-146-TSF	0.0308 mg/L X	0.015 mg/L
	12-5	HS-GL-DF	0.00843 mg/L	0.015 mg/L
	12-6	HS-GL-SF1	<0.001 mg/L	0.015 mg/L
	12-7	HS-GL-SF2	<0.001 mg/L	0.015 mg/L
	12-8	HS-BL-DF1	<0.001 mg/L	0.015 mg/L

ENVIRONMENTAL LABWORKS, INC.

ELAP #10824

Catskill High School/Middle School - 09301606C

PARAMETER EPA 200.8	ID	LOCATION	RESULTS	ACTION LEVEL
Lead	12-9	HS-BL-Coach	<0.001 mg/L	0.015 mg/L
	12-10	HS-BL-DF2	0.00679 mg/L	0.015 mg/L
	13-1	HS-BL-SF1	<0.001 mg/L	0.015 mg/L
	13-2	HS-BL-SF2	<0.001 mg/L	0.015 mg/L
	13-3	HS-BL-SF3	<0.001 mg/L	0.015 mg/L
	13-4	HS-157-SF1	0.0194 mg/L X	0.015 mg/L
	13-5	HS-157-SF2	0.0898 mg/L X	0.015 mg/L
	13-6	HS-FIT-DF	<0.001 mg/L	0.015 mg/L
	13-7	HS-FIT-RRF	<0.001 mg/L	0.015 mg/L
	13-8	HS-160-DF	<0.001 mg/L	0.015 mg/L
	13-9	HS-160-BRRF	<0.001 mg/L	0.015 mg/L
	13-10	HS-160-GRRF	<0.001 mg/L	0.015 mg/L
	14-1	HS-AUD-BRRF1	0.00474 mg/L	0.015 mg/L
	14-2	HS-AUD-BRRF2	0.00316 mg/L	0.015 mg/L
	14-3	HS-AUD-GRRF1	<0.001 mg/L	0.015 mg/L
	14-4	HS-AUD-GRRF2	0.00317 mg/L	0.015 mg/L
	14-5	HS-169-SF1	0.00427 mg/L	0.015 mg/L
	14-6	HS-169-SF2	0.00127 mg/L	0.015 mg/L
	14-7	HS-169-SF3	0.00173 mg/L	0.015 mg/L
	14-8	HS-169-SF4	0.00100 mg/L	0.015 mg/L
	14-9	BO-SF	<0.001 mg/L	0.015 mg/L
	14-10	BO-RR2	<0.001 mg/L	0.015 mg/L
	15-1	BO-RR1	0.00106 mg/L	0.015 mg/L
	15-2	BO-CB-WC	<0.001 mg/L	0.015 mg/L
	15-3	SO-RR1	0.00346 mg/L	0.015 mg/L
	15-4	SO-RR2	0.00384 mg/L	0.015 mg/L
	15-5	SO-CB-WC	<0.001 mg/L	0.015 mg/L
	20-1	MS-24-SC2	0.0282 mg/L X	0.015 mg/L
	20-2	MS-24-SC3	0.0504 mg/L X	0.015 mg/L

PO Box 733
Marlboro, NY 12542
Phone 845-236-7823
Fax 845-236-3911
ELAP #10824

ENVIRONMENTAL LABWORKS, INC.

Catskill High School/Middle School - 09301606C

PARAMETER				
EPA 200.8	ID	LOCATION	RESULTS	ACTION LEVEL
Lead	20-3	MS-24-SC4	0.0178 mg/L X	0.015 mg/L
	20-4	MS-24-SC5	0.100 mg/L X	0.015 mg/L
	20-5	MS-24-SC6	0.0790 mg/L X	0.015 mg/L
	20-6	MS-24-TSF	0.0996 mg/L X	0.015 mg/L

X - Value exceeds Maximum Contaminant Level or other Regulatory Level.

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #10854. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

If you have any questions or require any additional services, please do not hesitate to contact us at 845-236-7823.

Thank you,

Trudie Lund, for
Anthony J. Falco
Laboratory Director