

**ENVIRONMENTAL LABWORKS, INC.**

October 20, 2016

Mr. John Willabay  
 Catskill Central School District  
 347 West Main St.  
 Catskill, NY 12414

Dear Mr. Willabay,

The following are results of the analyses performed on water samples from **Catskill High School/Middle School, 341-345 West Main St., Catskill, NY** received at the laboratory on 09/30/16.

Date/Time Collected: 09/28/16 5:40-7:27am First Draw  
 09/29/16 4:50-5:10am First Draw  
 Collected By: J. Willabay  
 Sample ID: 09301606B:6-1 to 10-10  
 Secondary Lab ID: CS163045-91

PARAMETER	ID	LOCATION	RESULTS	ACTION LEVEL
EPA 200.8				
Lead	6-1	MS-7UT-SF	0.00513 mg/L	0.015 mg/L
	6-2	MS-7H-DF1	<0.001 mg/L	0.015 mg/L
	6-4	MS-11H-DF1	<0.001 mg/L	0.015 mg/L
	6-5	MS-11H-DF2	<0.001 mg/L	0.015 mg/L
	6-6	HS-MO-SF	<0.001 mg/L	0.015 mg/L
	6-7	HS-MO-RRF	<0.001 mg/L	0.015 mg/L
	6-8	HS-LRR1-SF	<0.001 mg/L	0.015 mg/L
	6-9	HS-LRR2-SF	<0.001 mg/L	0.015 mg/L
	6-10	HS-FAC-SF	<0.001 mg/L	0.015 mg/L
	7-1	HS-139-SCF1	0.0127 mg/L	0.015 mg/L
	7-2	HS-139-SCF2	0.00163 mg/L	0.015 mg/L
	7-3	HS-139-SCF3	0.00620 mg/L	0.015 mg/L
	7-4	HS-139-SCF4	0.00838 mg/L	0.015 mg/L
	7-5	HS-139-SCF5	0.00770 mg/L	0.015 mg/L
	7-6	HS-139-PRF	0.0132 mg/L	0.015 mg/L
	7-7	HS-130-WRRF	0.0285 mg/L	0.015 mg/L <b>X</b>
	7-8	HS-130-MRRF	0.00156 mg/L	0.015 mg/L
	7-9	HS-1BRRF1	0.00138 mg/L	0.015 mg/L

**ENVIRONMENTAL LABWORKS, INC.**

ELAP #10824

Catskill High School/Middle School - 09301606B

PARAMETER EPA 200.8	ID	LOCATION	RESULTS	ACTION	LEVEL
Lead	7-10	HS-1BRRF2	<0.001 mg/L		0.015 mg/L
	8-1	HS-1BRR-DF	<0.001 mg/L		0.015 mg/L
	8-3	HS-1GRR-SF1	<0.001 mg/L		0.015 mg/L
	8-4	HS-1GRR-SF2	<0.001 mg/L		0.015 mg/L
	8-5	HS-2GRR-DF	<b>0.00237</b> mg/L		0.015 mg/L
	8-6	HS-2GRR-SF1	<b>0.00320</b> mg/L		0.015 mg/L
	8-7	HS-2GRR-SF2	<b>0.00104</b> mg/L		0.015 mg/L
	8-9	HS-2BRR-SF1	<0.001 mg/L		0.015 mg/L
	8-10	HS-2BRR-SF2	<0.001 mg/L		0.015 mg/L
	9-1	CA-MO-SF	<0.001 mg/L		0.015 mg/L
	9-2	CA-BRRF	<0.001 mg/L		0.015 mg/L
	9-3	CA-GRRF	<0.001 mg/L		0.015 mg/L
	9-4	CA-NRRF	<0.001 mg/L		0.015 mg/L
	9-5	CA-NCB-WC	<0.001 mg/L		0.015 mg/L
	9-6	CA-268-SF	<0.001 mg/L		0.015 mg/L
	9-7	CA-269-SF	<0.001 mg/L		0.015 mg/L
	9-8	MS-OS-RRF-ADA	<0.001 mg/L		0.015 mg/L
	9-9	MS-OS-BRRF	<b>0.00120</b> mg/L		0.015 mg/L
	9-10	MS-OS-GRRF	<b>0.00230</b> mg/L		0.015 mg/L
	10-1	HS-140-SCF1	<b>0.0196</b> mg/L	<b>X</b>	0.015 mg/L
	10-2	HS-140-SCF2	<b>0.0157</b> mg/L	<b>X</b>	0.015 mg/L
	10-3	HS-140-SCF3	<b>0.0121</b> mg/L		0.015 mg/L
	10-4	HS-140-TSF	<b>0.0497</b> mg/L	<b>X</b>	0.015 mg/L
	10-5	HS-140-PRF	<b>0.0278</b> mg/L	<b>X</b>	0.015 mg/L
	10-6	HS-142-SCF1	<b>0.0234</b> mg/L	<b>X</b>	0.015 mg/L
	10-7	HS-142-SCF2	<b>0.0145</b> mg/L		0.015 mg/L
	10-8	HS-142-SCF3	<b>0.0206</b> mg/L	<b>X</b>	0.015 mg/L
	10-9	HS-142-TSF	<b>0.0705</b> mg/L	<b>X</b>	0.015 mg/L
	10-10	HS-144-TSF	<b>0.00345</b> mg/L		0.015 mg/L

PO Box 733  
Marlboro, NY 12542  
Phone 845-236-7823  
Fax 845-236-3911  
ELAP #10824

## **ENVIRONMENTAL LABWORKS, INC.**

---

**Catskill High School/Middle School - 09301606B**

**X** - Value exceeds Maximum Contaminant Level or other Regulatory Level.

The data contained in this report were obtained using EPA or other approved methodologies. This laboratory or any outside laboratory used are NYSDOH certified for these analyses. Vendor laboratory used was ELAP #10854. The results in this report apply to the samples received by the laboratory, analyzed in accordance with the chain of custody document. This analytical report may only be reproduced in its entirety.

If you have any questions or require any additional services, please do not hesitate to contact us at 845-236-7823.

Thank you,

*Trudie Lund*, for  
Anthony J. Falco  
Laboratory Director