













Lead Water Analysis 2016

Building	Location	Date	Time	Results	Limit .015 mg/L	Pass/Fail	Action	Date	Time	Pass/Fail	Action
ES 18-1	204-DF-E	9.21.16	7.56 A	<0.001	0.015	Pass	Not Req				
ES 18-2	204-SF-E	9.21.16	7.57 A	<0.001	0.015	Pass	Not Req				
ES 18-3	204-RRF-E	9.21.16	7.58 A	<0.001	0.015	Pass	Not Req				
ES 18-4	2RH-DF1-E	9.21.16	8.01 A	<0.001	0.015	Pass	Not Req				
ES 18-5	2RH-DF2-E	9.21.16	8.02 A	<0.001	0.015	Pass	Not Req				
ES 18-6	2RH-GRR-SF1-E	9.21.16	8.05 A	<0.001	0.015	Pass	Not Req				
ES 18-7	2RH-GRRF-SF2-E	9.21.16	8.06 A	<0.001	0.015	Pass	Not Req				
ES 18-8	2RH-BRR-SF1-E	9.21.16	8.09 A	<0.001	0.015	Pass	Not Req				
ES 18-9	2RH-BRR-SF2-E	9.21.16	8.10 A	<0.001	0.015	Pass	Not Req				
ES 18-10	THIS LINE NOT USED FOR DATA										
ES 19-1	2BH-DF1-E	9.21.16	8.13 A	<0.001	0.015	Pass	Not Req				
ES 19-2	2BH-DF2-E	9.21.16	8.14 A	<0.001	0.015	Pass	Not Req				
ES 19-3	2BH-GRR-SF1-E	9.21.16	8.17 A	<0.001	0.015	Pass	Not Req				
ES 19-4	2BH-GRR-SF2-E	9.21.16	8.18 A	<0.001	0.015	Pass	Not Req				
ES 19-5	2BH-BRR-SF1-E	9.21.16	8.20 A	<0.001	0.015	Pass	Not Req				
ES 19-6	2BH-BRR-SF2-E	9.21.16	8.21 A	<0.001	0.015	Pass	Not Req				
ES 19-7	219-DF-E	9.21.16	8.25 A	<0.001	0.015	Pass	Not Req				
ES 19-8	219-SF1-E	9.21.16	8.26 A	0.00208	0.015	Pass	Not Req				
ES 19-9	219-SF2-E	9.21.16	8.27 A	0.00162	0.015	Pass	Not Req				
ES 19-10	219-SF3-E	9.21.16	8.28 A	<0.001	0.015	Pass	Not Req				
ES 20-1	216-RRF-E	9.21.16	8.33 A	<0.001	0.015	Pass	Not Req				
ES 20-2	200A-SF-E	9.21.16	8.37 A	0.00737	0.015	Pass	Not Req				
ES 20-3	233-SF1-E	9.21.16	10.00 A	0.00143	0.015	Pass	Not Req				
ES 20-4	233-RRF-1	9.21.16	10.01 A	0.00792	0.015	Pass	Not Req				
ES 20-5	233-SF2-E	9.21.16	10.03 A	0.00606	0.015	Pass	Not Req				
ES 20-6	216-CB-WC-E	9.21.16	10.07 A	<0.001	0.015	Pass	Not Req				
ES 21-1	KIT-PFF1-E	10.04.16	7.09 A	<0.001	0.015	Pass	Not Req				
ES 21-2	KIT-PFF2-E	10.04.16	7.16 A	<0.001	0.015	Pass	Not Req				
ES 21-3	KIT-GUSF-E	10.04.16	7.17 A	<0.001	0.015	Pass	Not Req				
END OF ELEMENTARY TESTING SHIPPED TO ENVIRONMENTAL LABWORKS 9.21.16											
ES 3-4	RETESTED WITH SECONDARY SCHOOL PHASE TO BE SHIPPED 9.30.16										

Lead Water Analysis 2016

Building	Location	Date	Time	Results	Limit .015 mg/L	Pass/Fail	Action	Date	Time	Pass/Fail	Action
HM 1	HS-N-RRF--MS	9.27.16	5.36 A	<0.001	0.015	Pass	Not Req				
HM 2	HS-N-SF-MS	9.27.16	5.39 A	0.00104	0.015	Pass	Not Req				
HM 3	HS-N-WC-MS	9.27.16	5.40 A	<0.001	0.015	Pass	Not Req				
HM 4	NO DATA RECORDED ON THIS LINE										
HM 5	MSC-GRR-SF1	9.27.16	5.44 A	<0.001	0.015	Pass	Not Req				
HM 7	MSC-BRR-SF1	9.27.16	5.49 A	<0.001	0.015	Pass	Not Req				
HM 8	MSC-BRR-SF2	9.27.16	5.51 A	<0.001	0.015	Pass	Not Req				
HM 9	MSC-SF1	9.27.16	5.53 A	0.0017	0.015	Pass	Not Req				
HM 10	MS-DLRR-SF	9.27.16	5.57 A	<0.001	0.015	Pass	Not Req				
HM 1-1	HS-LWR-SF	9.27.16	6.00 A	0.00482	0.015	Pass	Not Req				
HM 1-2	MS-103-SF1	9.27.16	6.05 A	<0.001	0.015	Pass	Not Req				
HM 1-3	MS-103-SF2	9.27.16	6.06 A	<0.001	0.015	Pass	Not Req				
HM 1-4	MS-103-SF3	9.27.16	6.08 A	0.00105	0.015	Pass	Not Req				
HM 1-5	MS-103-SF4	9.27.16	6.09 A	<0.001	0.015	Pass	Not Req				
HM 1-6	MS-1BRR-SF1	9.27.16	6.17 A	<0.001	0.015	Pass	Not Req				
HM 1-7	MS-1BRR-SF2	9.27.16	6.19 A	<0.001	0.015	Pass	Not Req				
HM 1-8	MS-WS-SF1	9.27.16	6.22 A	0.282	0.015	Fail	Common	Wood Shop Sink			Non Potable sign
HM 1-9	MS-WS-SF2	9.27.16	6.23 A	0.00164	0.015	Pass	Common	Wood Shop Sink			Non Potable sign
HM 1-10	MS-WS-SF3	9.27.16	6.24 A	0.00184	0.015	Pass	Common	Wood Shop Sink			Non Potable sign
HM 2.1	MS-BL-SF1	9.27.16	6.30 A	0.00401	0.015	Pass	Not Req				
HM 2-2	MS-BL-DF1	9.27.16	6.31 A	<0.001	0.015	Pass	Not Req				
HM 2-3	MS-CcH-RRF	9.27.16	6.32 A	0.0088	0.015	Pass	Not Req				
HM 2-4	MS1-GL-SF1	9.27.16	6.38 A	<0.001	0.015	Pass	Not Req				
HM 2-5	MS1-GL-SF2	9.27.16	6.39 A	<0.001	0.015	Pass	Not Req				
HM 2-6	MS1-GL-DF	9.27.16	6.40 A	<0.001	0.015	Pass	Not Req				
HM 2-7	MS1-GRR-SF1	9.27.16	6.42 A	<0.001	0.015	Pass	Not Req				
HM 2-8	MS1-GRR-SF2	9.27.16	6.43 A	0.00114	0.015	Pass	Not Req				
HM 2-9	MS1-GRR-SF3	9.27.16	6.44 A	<0.001	0.015	Pass	Not Req				
HM 2-10	MS23-SF1	9.27.16	6.51 A	0.007	0.015	Pass	Not Req				
Building	Location	Date	Time	Results	Limit .015 mg/L	Pass/Fail	Action	Date	Time	Pass/Fail	Action



Lead Water Anlysis 2016

HM	3-1	MS-23-SF2	9.27.16	6.52 A	0.00162	0.015	Pass	Not Req				
HM	3-2	MS-23-SF3	9.27.16	6.53 A	0.00321	0.015	Pass	Not Req				
HM	3-3	MS-23-SF4	9.27.16	6.54 A	0.00135	0.015	Pass	Not Req				
HM	3-4	MS-24-DF	9.27.16	7.01 A	<0.001	0.015	Pass	Not Req				
HM	3-5	MSC-GRR-SF2	9.27.16	7.07 A	0.165	0.015	Fail		Girls Restroom Faucet		Non Potable Sign	
HM	3-6	112-DF-E CES	9.27.16	7.40 A	<0.001	0.015	Pass	Not Req				
HM	3-7	HS-KPSF	9.28.16	4.31 A	0.0014	0.015	Pass	Not Req				
HM	3-8	HS-KPFF	9.28.16	4.34 A	0.00271	0.015	Pass	Not Req				
HM	3-9	HS-KSF1	9.28.16	4.36 A	<0.001	0.015	Pass	Not Req				
HM	3-10	HS-KSF2	9.28.16	4.37 A	0.00137	0.015	Pass	Not Req				
HM	4-1	MS-C-DF	9.28.16	4.45 A	<0.001	0.015	Pass	Not Req				
HM	4-2	MS-24-SCF1	9.28.16	4.52 A	<0.001	0.015	Pass	Not Req				
HM	4-9	MS-26-TSCF	9.28.16	4.58 A	0.00489	0.015	Pass	Not Req				
HM	4-10	MS-26PRSF	9.28.16	5.00 A	0.0401	0.015	Fail		Chem Prep Room		Non Potable Sign	
HM	5-1	MS-FAC-LSF1	9.28.16	5.07 A	0.00169	0.015	Pass	Not Req				
HM	5-2	MS-FAC-MSF1	9.28.16	5.09 A	0.00129	0.015	Pass	Not Req				
HM	5-3	MS-2GRR-SF1	9.28.16	5.13 A	<0.001	0.015	Pass	Not Req				
HM	5-4	MS-2GRR-SF2	9.28.16	5.14 A	0.00148	0.015	Pass	Not Req				
HM	5-5	MS-2GRR-DF	9.28.16	5.15 A	<0.001	0.015	Pass	Not Req				
HM	5-6	MS-2GRR-SF3	9.28.16	5.16 A	<0.001	0.015	Pass	Not Req				
HM	5-7	MS-3SF	9.28.16	5.25 A	0.0131	0.015	Pass	Not Req				
HM	5-8	MS-MO-RRF	9.28.16	5.29 A	0.00942	0.015	Pass	Not Req				
HM	5-9	MS-2BRR-SF1	9.28.16	5.31 A	<0.001	0.015	Pass	Not Req				
HM	5-10	MS-2BRR-SF2	9.28.16	5.32 A	<0.001	0.015	Pass	Not Req				
Building	Location		Date	Time	Results	Limit .015 mg/L	Pass/Fail	Action	Date	Time	Pass/Fail	Action
HM	6-1	MS-7UTSF	9.28.16	5.40 A	0.00513	0.015	Pass	Not Req				
HM	6-2	MS-7HDF1	9.28.16	5.43 A	<0.001	0.015	Pass	Not Req				
HM	6-3	MS-7HDF2	X	X	INOPERATIVE WILL HAVE TO BE TESTED AT A LATER DATE							
HM	6-4	MS-11HDF1	9.28.16	5.47 A	<0.001	0.015	Pass	Not Req				
HM	6-5	MS-11HDF2	9.28.16	5.48 A	<0.001	0.015	Pass	Not Req				
HM	6-6	HS-MO-SF	9.28.16	5.53 A	<0.001	0.015	Pass	Not Req				

Lead Water Anlysis 2016

HM 6-7	HS-MO-RRF	9.28.16	5.55 A	<0.001	0.015	Pass	Not Req					
HM 6-8	HS-LRR1-SF	9.28.16	5.57 A	<0.001	0.015	Pass	Not Req					
HM 6-9	HS-LRR2-SF	9.28.16	5.58 A	<0.001	0.015	Pass	Not Req					
HM 6-10	HS-FAC-SF	9.28.16	6.02 A	<0.001	0.015	Pass	Not Req					
HM 7-1	HS-139-SCF1	9.28.16	6.07 A	0.0127	0.015	Pass	Not Req					
HM 7-2	HS-139-SCF2	9.28.16	6.08 A	0.00163	0.015	Pass	Not Req					
HM 7-3	HS-139-SCF3	9.28.16	6.09 A	0.0062	0.015	Pass	Not Req					
HM 7-4	HS-139-SCF4	9.28.16	6.10 A	0.00838	0.015	Pass	Not Req					
HM 7-5	HS-139-SCF5	9.28.16	6.11 A	0.0077	0.015	Pass	Not Req					
HM 7-6	HS-139-PRF	9.28.16	6.19 A	0.0132	0.015	Pass	Not Req					
HM 7-7	HS-130-WRRF	9.28.16	6.21 A	0.0285	0.015	Fail		Womans Rest Room Sink		Non Potable Sign		
HM 7-8	HS-130-MRRF	9.28.16	6.23 A	0.00156	0.015	Pass	Not Req					
HM 7-9	HS-1BRRF1	9.28.16	6.27 A	0.00138	0.015	Pass	Not Req					
HM 7-10	HS-1BRRF2	9.28.16	6.28 A	<0.001	0.015	Pass	Not Req					
HM 8-1	HS-1BRR-DF	9.28.16	6.31 A	<0.001	0.015	Pass	Not Req					
HM 8-2	HS-1GRR-DF	X	X			FOUNTAIN INOPERATIVE AT THIS TIME-TO BE REPLACED						
HM 8-3	HS-1GRR-SF1	9.28.16	6.35 A	<0.001	0.015	Pass	Not Req					
HM 8-4	HS-1GRR-SF2	9.28.16	6.36 A	<0.001	0.015	Pass	Not Req					
HM 8-5	HS-2GRR-DF	9.28.16	6.39 A	0.00237	0.015	Pass	Not Req					
HM 8-6	HS-2GRR-SF1	9.28.16	6.41 A	0.0032	0.015	Pass	Not Req					
HM 8-7	HS-2GRR-SF2	9.28.16	6.42 A	0.00104	0.015	Pass	Not Req					
HM 8-8	HS-2BRR-DF	X	X			FOUNTAIN INOPERATIVE AT THIS TIME-TO BE REPLACED						
HM 8-9	HS-2BRR-SF1	9.28.16	6.45 A	<0.001	0.015	Pass	Not Req					
HM 8-10	HS-2BRR-SF2	9.28.16	6.46 A	<0.001	0.015	Pass	Not Req					
Building	Location	Date	Time	Results	Limit .015 mg/L	Pass/Fail	Action	Date	Time	Pass/Fail	Action	
HM 9-1	CA-MO-SF	9.28.16	6.52 A	<0.001	0.015	Pass	Not Req					
HM 9-2	CA-BRRF	9.28.16	6.55 A	<0.001	0.015	Pass	Not Req					
HM 9-3	CA-GRRF	9.28.16	6.58 A	<0.001	0.015	Pass	Not Req					
HM 9-4	CA-NRRF	9.28.16	6.59 A	<0.001	0.015	Pass	Not Req					
HM 9-5	CA-NCB-WC	9.28.16	7.01 A	<0.001	0.015	Pass	Not Req					
HM 9-6	CA-268-SF	9.28.16	7.04 A	<0.001	0.015	Pass	Not Req					

Lead Water Anlysis 2016

HM 9-7	CA-269-SF	9.28.16	7.06 A	<0.001	0.015	Pass	Not Req				
HM 9-8	MS-OSRRF-ADA	9.28.16	7.23 A	<0.001	0.015	Pass	Not Req				
HM 9-9	MS-OS-BRRF	9.28.16	7.26 A	0.0012	0.015	Pass	Not Req				
HM 9-10	MS-OS-GRRF	9.28.16	7.27 A	0.0023	0.015	Pass	Not Req				
HM 10-1	HS-140-SCF1	9.29.16	4.50 A	0.0196	0.015	Fail		Science Lab Faucet			Non Potable Sign
HM 10-2	HS-140-SCF2	9.29.16	4.51 A	0.0157	0.015	Fail		Science Lab Faucet			Non Potable Sign
HM 10-3	HS-140-SCF3	9.29.16	4.52 A	0.0121	0.015	Pass	Not Req				
HM 10-4	HS-140-TSF	9.29.16	4.53 A	0.0497	0.015	Fail		Teachers Scien Lab Faucet			Non Potable Sign
HM 10-5	HS-140-PRF	9.29.16	4.57 A	0.0278	0.015	Fail		Prep room Faucet			Non Potable Sign
HM 10-6	HS-142-SCF1	9.29.16	5.01 A	0.0234	0.015	Fail		Science Lab Faucet			Non Potable Sign
HM 10-7	HS-142-SCF2	9.29.16	5.02 A	0.0145	0.015	Pass	Not Req				
HM 10-8	HS-142-SCF3	9.29.16	5.03 A	0.0206	0.015	Fail		Science Lab Faucet			Non Potable Sign
HM 10-9	HS-142-TSF	9.29.16	5.04 A	0.0705	0.015	Fail		Teachers Scien Lab Faucet			Non Potable Sign
HM 10-10	HS-144-TSF	9.29.16	5.10 A	0.00345	0.015	Pass	Not Req				
HM 11-1	HS-144-PRF	9.29.16	5.12 A	0.0616	0.015	Fail		Prep room Faucet			Non Potable Sign
HM 11-2	HS-146-SC1	9.29.16	5.19 A	0.0346	0.015	Fail		Science Lab Faucet			Non Potable Sign
HM 11-3	HS-146-SC2	9.29.19	5.20 A	0.0246	0.015	Fail		Science Lab Faucet			Non Potable Sign
HM 11-4	HS-146-SC3	9.29.16	5.21 A	0.0247	0.015	Fail		Science Lab Faucet			Non Potable Sign
HM 11-5	HS-146-SC4	9.29.16	5.22 A	0.0705	0.015	Fail		Science Lab Faucet			Non Potable Sign
HM 11-6	HS-146-SC5	9.29.16	5.23 A	0.0384	0.015	Fail		Science Lab Faucet			Non Potable Sign
HM 11-7	HS-146-SC6	9.29.16	5.24 A	0.055	0.015	Fail		Science Lab Faucet			Non Potable Sign
HM 11-8	HS-146-SC7	9.29.16	5.25 A	0.26	0.015	Fail		Science Lab Faucet			Non Potable Sign
HM 11-9	HS-146-SC8	9.29.16	5.26 A	0.228	0.015	Fail		Science Lab Faucet			Non Potable Sign
HM 11-10	HS-146-SC9	9.29.16	5.27 A	0.0116	0.015	Pass	Not Req				
Building	Location	Date	Time	Results	Limit .015 mg/L	Pass/Fail	Action	Date	Time	Pass/Fail	Action
HM 12-1	HS-146-SC10	9.29.16	5.28 A	0.0179	0.015	Fail		Science Lab Faucet			Non Potable Sign
HM 12-2	HS-146-SC11	9.29.16	5.29 A	0.0422	0.015	Fail		Science Lab Faucet			Non Potable Sign
HM 12-3	HS-146-SC12	9.29.16	5.30 A	0.0498	0.015	Fail		Science Lab Faucet			Non Potable Sign
HM 12-4	HS-146-TSF	9.29.16	5.31 A	0.0308	0.015	Fail		Teachers Scien Lab Faucet			Non Potable Sign
HM 12-5	HS-GL-DF	9.29.16	5.45 A	0.00843	0.015	Pass	Not Req				
HM 12-6	HS-GL-SF1	9.29.16	5.46 A	<0.001	0.015	Pass	Not Req				



